



FDA / IMS #36-B-00155

Packaging Consultants International

1101 State Fair Boulevard, Syracuse, NY 13209
Tel: 315-468-6234 www.pcilabs.com Fax: 315-468-6235



Testing Lab A2LA Certificate #3497.01

WATER TEST REPORT (SM 9223 & 9215B)

Samples Received From: Bob's Dairy - Syracuse, NY
Report Submitted To: John Dow

Date Sampled: 3/15/2021
Time Sampled: 1:20 PM
Date Received: 3/16/2021
Date Analyzed: 3/16/2021
Time Analyzed: 10:30 AM

Purchase Order: 12345-21
Test Report ID: 999921
Analyst ID(s): 4 / 15
Sample ID(s): 2345
Date Reported: 8/6/2021

Sample ID/ Location ¹	Heterotrophic Plate Count/mL Pour Plate Method @ 35°C/48h	Colisure Enzyme Substrate Method Total Coliforms & E. Coli per 100 mL @ 35°C/24-48h		Mold/Yeast Plate Count/mL Pour Plate Method @ 25°C/5 days
		Total Coliforms	E. coli	
1 . Restroom Handsink	Not Found	Not Found	Not Found	<1
2 . Breakroom faucet	Positive	Present	Not Found	5 mold; 2 yeast
3 . Water Fountain	Positive	Present	Present	10 mold; <1 yeast
Sample Report Only				

Standards & Interpretation:

Heterotrophic Plate Count: Not Found if <500 CFU/mL; Positive if ≥500 CFU/mL - No Regulatory Standard Limit

Total Coliform & E. Coli: Not Found per 100 mL sample: <1/100 mL; Present per 100 mL sample: ≥1/100 mL - Regulatory Standard is Absent/Not Found/<1/100 mL

Additional microbiological testing standards are determined by the report recipient organization's Quality & Food Safety Programs

¹ The results stated relate only to the items tested, for the sample(s) as received; Samples were received in proper condition and the reported results conform to applicable accreditation standards unless otherwise noted.

Authorizations:

Melissa Rice, Lab/Quality Manager
melissa@pcilabs.com

Patrick A. Frontale, President
patrick@pcilabs.com

References:

Section 6.020, Standard Plate Count Method (Class O), from Standard Methods for the Examination of Dairy Products, 17th ed., American Public Health Association, 2004.

Section 8.112, Acidified Potato Dextrose (Glucose) Agar, from Standard Methods for the Examination of Dairy Products, 17th ed., American Public Health Association, 2004.

Section 9215 B., Heterotrophic Plate Count (Pour Plate Method), from Standard Methods for the Examination of Water and Wastewater, 23rd ed., American Public Health Association, 2017.

Section 9223, Enzyme Substrate Coliform Test, from Standard Methods for the Examination of Water and Wastewater, 23rd ed., American Public Health Association, 2017.